

PROPOSED
COMMUNITY HALL
FGFL = 53.82

SITE SERVICES SYMBOLS

DENOTES TRENCH REQUIRED FOR DUCTING FOR THE UNDERGROUND POWER SUPPLY TO THE LIGHTING STANDARDS. (SEE DETAIL "C" ON DRAWING FOR INFORMATION ON TRENCH REQUIRED).

DENOTES TRENCH REQUIRED FOR THE DUCTING FOR UNDERGROUND SUPPLY FOR THE EV CHARGERS. (SEE DETAIL "C" ON DRAWING FOR INFORMATION ON TRENCH REQUIRED).

DENOTES TRENCH REQUIRED FOR THE DUCTING FOR UNDERGROUND SUPPLY FOR THE DATA NETWORK BUILDING. (SEE DETAIL "C" ON DRAWING FOR INFORMATION ON TRENCH REQUIRED).


DENOTES TRENCH REQUIRED FOR THE UNDERGROUND GAS PRESSURE SUPPLY FROM THE NETWORKS TO THE BUILDING. (SEE DETAIL "C" ON DRAWING FOR INFORMATION ON TRENCH REQUIRED).

NEW EXTERNAL ACCESS CHAMBER FOR SERVICES WHICH SHALL BE RECESSED INTO THE GROUND. (SEE DETAIL "C" ON DRAWING FOR INFORMATION ON TRENCH REQUIRED).

NEW LIGHTING COLUMN 6' / 8' ON THE NEW LED LIGHT COLUMN ON A SINGLE OUTLET. (SEE DETAIL "C" ON THE LIGHT FITTING, ALLOW FOR NEW CABLEING TO THE NEW LIGHTING FROM THE NEW MAIN BOARD. LIGHTING COLUMN SHALL BE 6000MM HIGH. IN SOME INSTANCES A POLE MOUNTED OUTLET CABLES SHALL ALSO BE INSTALLED ON THE LIGHTING COLUMN BY OTHERS. (SEE DETAIL "C" ON DRAWING FOR INFORMATION ON ATTENDANCES REQUIRED).

SUPPLY AND INSTALL EV CHARGER
GPR-10M-12220V-1N

[illegible]

<p>M&E CONSULTANT</p>  <p>GALILEO ENERGY SERVICES UNIT A6, M4 BUSINESS PARK, MAYNOOTH ROAD, CELBRIDGE, CO. KILDARE. Tel: 01-6274103 www.galileoenergy.ie</p> <p style="text-align: right;">Copyright ©</p>			
<p>Drawing Status</p> <p>PRELIMINARY</p>			
<p>Job Title</p> <p>POBAL LE CHEILE PROJECT BALLYMAHON, CO LONGFORD</p>			
<p>Drawing Title</p> <p>DRAFT MECHANICAL AND ELECTRICAL SITE SERVICES LAYOUT.</p>			
<p>Architect</p> <p>KENNY LYONS ASSOCIATES BLOCK 6, CENTRAL BUSINESS PARK, TULLAMORE, CO OFFALY 0579324241</p>			
<p>Scale: 1:125 @ A0</p>		<p>Drawing By: GERD BENNDORF</p>	
<p>Job No. 24-015</p>		<p>Drawing No. ME(S001)</p>	<p>Rev. P2</p>